



**S.N.D.T. Women's University**  
**Sir Vithaldas Thackersey College of Home Science**

**(Autonomous)**

NAAC Re-accredited 'A' Grade

UGC Honor - College with Potential for Excellence



SVT/Quotation/2019-20/1209

Date: 17.02.2020

SUB: Quotation for Fire Extinguishers under College Development Fund grant at Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai.

Madam /Sir,

Sealed quotations are invited for Fire Extinguishers under College Development Fund grant at Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai. Interested vendors are requested to submit their quote in the format given in Annexure A on company letter head. Quotation should be submitted to The Principal, Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai on or before 26<sup>th</sup> of February, 2020 (before 1.00 p.m.)

Sir Vithaldas Thackersey College of Home Science (Autonomous), SNDT Women's University, Santacruz (West), Mumbai reserves the right to reject any or all quotations without assigning any reasons thereof.

Dr. Jagmeet Madan  
(Principal)

SVT/Quotation/2019-20/1209


Date: 17.02.2020

SUB: Quotation for Fire Extinguishers under College Development Fund grant at Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai.

Madam /Sir,

Sealed quotations are invited for Fire Extinguishers under College Development Fund grant at Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai. Interested vendors are requested to submit their quote in the format given in Annexure A on company letter head. Quotation should be submitted to The Principal, Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai on or before 26<sup>th</sup> of February, 2020 (before 1.00 p.m.)

Sir Vithaldas Thackersey College of Home Science (Autonomous), SNDT Women's University, Santacruz (West), Mumbai reserves the right to reject any or all quotations without assigning any reasons thereof.

  
Dr. Jagmeet Madan  
(Principal)

SVT/Quotation/2019-20/1209

Date: 17.02.2020

**SUB: Quotation for Fire Extinguishers under College Development Fund grant at Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai.**

Madam /Sir,

Sealed quotations are invited for Fire Extinguishers under College Development Fund grant at Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai. Interested vendors are requested to submit their quote in the format given in Annexure A on company letter head. Quotation should be submitted to The Principal, Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai on or before 26<sup>th</sup> of February, 2020 (before 1.00 p.m.)

Sir Vithaldas Thackersey College of Home Science (Autonomous), SNDT Women's University, Santacruz (West), Mumbai reserves the right to reject any or all quotations without assigning any reasons thereof.

  
Dr. Jagmeet Madan  
(Principal)

(Offer should filled on letter head)  
Annexure A

To,  
The Principal,  
Sir Vithaldas Thackersey College of Home Science (Autonomous),  
SNDT Women's University,  
Juhu, Santacruz (West),  
Mumbai - 400 049.

SUB: Quotation for Fire Extinguishers under College Development Fund grant at Sir Vithaldas Thackersey College of Home Science (Autonomous) SNDT Women's University, Sir Vithaldas Vidyavihar Campus, Juhu Tara Road, Santacruz (West), Mumbai.

Respected Sir / Madam,

With reference to subject cited above we would like to furnish our quote with best rate possible as below :

TECHNICAL DATA SHEET AS PER IS15683		
Customer Name:		
ITEM : CO2 TYPE FIRE EXTINGUISHERS		
Details	2 KG	4.5 Kg
Total Weight	10 KG Approx	17 kg Approx
Diameter	95 mm	140 mm
Hose	HORN	1 M
Discharge time	More than 8 sec	More than 13 second
Service Pressure	120 kgf	120kgf
Discharge Mechanism	Controllable	Controllable
Working Temp	-20 °C to 60° C	-20 °C to 60° C
Applicable on	Class B & C	Class B & C
Ratings	21 B	55 B
Range	More than 2 Meters	More than 2 Meters
Valve Construction	Forging & Machining	Forging & Machining
Certifications	ISI	ISI
Sheet metal thickness	4 mm	4 mm
Total Cost		

CUSTOMER NAME:	
TECHNICAL SPECIFICATION OF FIRE EXTINGUISHER AS PER IS 15683	
NAME OF ITEM : ABC TYPE 2 KG CAPACITY FIRE EXTINGUISHER	
Capacity	2 kg
Extinguishing Agent	Powder(MAP90)
Type	Stored Pressure
Gross Weight	Approx. 3.4 kg
Can Height	355 mm
Diameter	110 mm
Discharge Time	More than 8 Seconds
Discharge	Nozzle
Range	More than 2 m
Applicable on	Class A,B,C
Fire rating	1A-21B
Cylinder Construction	Deep drawn & CO2 Mig welded
Valve Construction	Forging & Machining
Coating of Can	Epoxy Powder coating
Sheet Metal Thickness	1.2 mm
Certification	IS:15683
Total Cost	

CUSTOMER NAME:	
TECHNICAL SPECIFICATION OF FIRE EXTINGUISHER AS PER IS 15683	
NAME OF ITEM: ABC TYPE 4KG CAPACITY FIRE EXTINGUISHER	
Capacity	4Kg
Extinguishing Agent	Powder(MAP90)
Type	Stored Pressure
Gross Weight	Approx. 6.4 kg
Can Height	405 mm
Diameter	150 mm
Discharge Time	More than 9 Seconds
Discharge Hose	Nylon Wire Braided 400 mm
Range	More than 2 m
Applicable on	Class A,B,C
Fire rating	2A-55B
Cylinder Construction	Deep drawn & CO2 Mig welded
Valve Construction	Forging & Machining
Coating of Can	Epoxy Powder coating

Sheet Metal Thickness	1.2 mm
Certification	IS:15683
Total Cost	

CUSTOMER NAME:	
TECHNICAL SPECIFICATION OF FIRE EXTINGUISHER AS PER IS 15683	
NAME OF ITEM: ABC TYPE 6 KG CAPACITY FIRE EXTINGUISHER	
Capacity	6Kg
Extinguishing Agent	Powder(MAP90)
Type	Stored Pressure
Gross Weight	Approx. 8.6 kg
Can Height	460 mm
Diameter	150 mm
Discharge Time	More than 9 Seconds
Discharge Hose	400 mm
Range	More than 2 m
Applicable on	Class A,B,C
Fire rating	3A-89B
Cylinder Construction	Deep drawn & CO2 Mig welded
Valve Construction	Forging & Machining
Coating of Can	Epoxy Powder coating
Sheet Metal Thickness	1.2 mm
Certification	IS:15683
Total Cost	

All the terms and conditions given in notifications are studied thoroughly and accepted fully.

Thanking you,

Yours truly,

Name of the Company  
Signature of the Proprietor  
Date :

- Note : Please enclose
1. Self attested GST number copy ,
  2. Self attested PAN number copy,
  3. Declaration on the company letter head if GST is not applicable.